


PLAN VIEW FOR ELECTRICAL



OPERATOR SIDE



POWER SUPPLY FOR COMPRESSOR & LIGHTS (120/1/15AMP.)
 POWER SUPPLY FOR STEAM TABLE (120/1/15 AMP.)

*** ALL DIMENSIONS ARE ± 1/8"**

NEMA Receptacle Configurations	1 CIRCUIT FOR STEAM TABLE	1 CIRCUIT FOR COMPRESSOR & LIGHTS	ELECTRICALS : * TWO SEPARATE CIRCUIT REQUIRED. -1 CIRCUIT OF 120/1/15 AMP. FOR STEAM TABLE.(8.3 AMPS. X 1 CIRCUIT) -1 CIRCUIT OF 120/1/15 AMP. FOR COMPRESSOR & LIGHTS. (10.2 AMPS. X 1 CIRCUIT)
	TWO SEPARATE POWER SUPPLY REQUIRED	125V 5-15R	

UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS ARE IN INCHES	DRW. BY:	APP.D:
	DATE: 03-01-16	SHEET SIZE: C
TOLERANCES: XX ± 1/64 X ± .1 XX ± .01 XXX ± .005	CHK. BY:	SCALE: NTS
	CUSTOMER: MTY	
DWG. NO#	PROJECT: SUB-X	DESCRIPTION: 108" COMBO HOT/COLD UNIT-SUBX
REV.	DISCRIPTION	DATE BY
FILE NO. CMB108-1HW-ROO	REV. N	SHEET 1 OF 1